

## MQ15-X- Power male receptacle front mount


PVC 6x1,5 UL/CSA 0,50m


Flange male MQ15, 6-pole with multi-strand wire Front mounting Plastic housings with good resistance against chemicals and oils. The resistance to aggressive media should be individually tested for your application. Further details on request. Further cable lengths on request.


## Link to Product

Illustration










The information in this Product-PDF has been compiled with the utmost care. Liability for the correctness completeness and topicality of the information is restricted to gross negligence. Version: 2024-05-18 Murrelektronik by | Noorderlaan 147-b9 | B-2030 Antwerpen | Fon +32 (0)380 868 81 | Fax | shop@murrelektronik.be | shop.murrelektronik.be





Product may differ from Image

## 

Cable length	0,5 m
Side 1	
Mounting method	inserted, screwed
Coating contact	silver-plated
Family construction form	MQ15
Material contact	Copper alloy
No. of poles	6
Commercial data	
ECLASS-6.0	27279220
ECLASS-6.1	27279220
ECLASS-7.0	27440103
ECLASS-8.0	27440103
ECLASS-9.0	27440103
ECLASS-10.1	27440103
ECLASS-11.1	27440103
ECLASS-12.0	27440103
ETIM-5.0	EC002061
customs tariff number	85444290
GTIN	4048879830218
Packaging unit	1
Electrical data   Supply	
Operating voltage AC per power contact max.	600 V
Operating voltage AC per signal contact max.	63 V
Operating voltage DC per signal contact max.	63 V
Operating current per power contact max.	13 A
Operating current per signal contact max.	10 A
Diagnostics	
Status indication LED	no
Installation   Connection	
Mating cycles min.	500
Installation   Pin assignment	

The information in this Product-PDF has been compiled with the utmost care. Liability for the correctness completeness and topicality of the information is restricted to gross negligence. Version: 2024-05-18

Murrelektronik bv | Noorderlaan 147-b9 | B-2030 Antwerpen | Fon +32 (0)380 868 81 | Fax | shop@murrelektronik.be | shop.murrelektronik.be



Configuration	fully used
Device protection   Electrical	
Degree of protection (EN IEC 60529)	IP67
Protection NEMA	3, 4, 6P
Additional condition protection degree	inserted, screwed
Pollution Degree	3
Rated surge voltage	2,5 kV
Material group (IEC 60664-1)	
Mechanical data   Material data	
Coating housing	nickel plated
Material housing	Brass
Material contact carrier	РА
Mechanical data   Mounting data	
Looking techniques	bayonet-locking
Environmental characteristics   Climatic	
Operating temperature min.	-40 °C
Operating temperature max.	70 °C
Additional condition temperature range	depending on cable quality
Important installation notes	
Note on strain relief	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties.
Note on strain relief Note on bending radius	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties. <b>Attention:</b> Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.
	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be
Note on bending radius	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be
Note on bending radius Approvals	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.
Note on bending radius Approvals UL 50E	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.
Note on bending radius Approvals UL 50E Installation   Cable	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces. yes
Note on bending radius Approvals UL 50E Installation   Cable Cable identification	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces. yes P83
Note on bending radius Approvals UL 50E Installation   Cable Cable identification wire arrangement	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.         yes         P83         black 1, black 2, black 3, green-yellow, blue, blue
Note on bending radius Approvals UL 50E Installation   Cable Cable identification wire arrangement Material wire insulation	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.         yes         P83         black 1, black 2, black 3, green-yellow, blue, blue         PVC
Note on bending radius          Approvals         UL 50E         Installation   Cable         Cable identification         wire arrangement         Material wire insulation         Amount wires	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.         yes         P83         black 1, black 2, black 3, green-yellow, blue, blue         PVC         6
Note on bending radius         Approvals         UL 50E         Installation   Cable         Cable identification         wire arrangement         Material wire insulation         Amount wires         Outer diameter insulation	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.         yes         P83         black 1, black 2, black 3, green-yellow, blue, blue         PVC         6         3,1 mm
Note on bending radius         Approvals         UL 50E         Installation   Cable         Cable identification         wire arrangement         Material wire insulation         Amount wires         Outer diameter insulation         Outer diameter tolerance core insulation	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.         yes         P83         black 1, black 2, black 3, green-yellow, blue, blue         PVC         6         3,1 mm         ± 5 %
Note on bending radius         Approvals         UL 50E         Installation   Cable         Cable identification         wire arrangement         Material wire insulation         Amount wires         Outer diameter insulation         Outer diameter tolerance core insulation         Conductor crosssection (wire)	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.         yes         P83         black 1, black 2, black 3, green-yellow, blue, blue         PVC         6         3,1 mm         ± 5 %         1,5 mm²
Note on bending radius         Approvals         UL 50E         Installation   Cable         Cable identification         wire arrangement         Material wire insulation         Amount wires         Outer diameter insulation         Outer diameter tolerance core insulation         Conductor crosssection (wire)         AC withstand voltage (wire - wire)         Power frequency withstand voltage (wire -	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.         yes         P83         black 1, black 2, black 3, green-yellow, blue, blue         PVC         6         3,1 mm         ± 5 %         1,5 mm²         2,5 kV
Note on bending radius         Approvals         UL 50E         Installation   Cable         Cable identification         wire arrangement         Material wire insulation         Amount wires         Outer diameter insulation         Outer diameter tolerance core insulation         Conductor crosssection (wire)         AC withstand voltage (wire - wire)         Power frequency withstand voltage (wire - jacket)	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.         yes         P83         black 1, black 2, black 3, green-yellow, blue, blue         PVC         6         3,1 mm         ± 5 %         1,5 mm²         2,5 kV         2,5 kV
Note on bending radius         Approvals         UL 50E         Installation   Cable         Cable identification         wire arrangement         Material wire insulation         Amount wires         Outer diameter insulation         Outer diameter tolerance core insulation         Conductor crosssection (wire)         AC withstand voltage (wire - wire)         Power frequency withstand voltage (wire - jacket)         Flame resistance	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.         yes         P83         black 1, black 2, black 3, green-yellow, blue, blue         PVC         6         3,1 mm         ± 5 %         1,5 mm²         2,5 kV         2,5 kV         IEC 60332-2-2   UL 1581 § 1100 FT2   UL 1581 § 1090
Note on bending radius         Approvals         UL 50E         Installation   Cable         Cable identification         wire arrangement         Material wire insulation         Amount wires         Outer diameter insulation         Outer diameter tolerance core insulation         Conductor crosssection (wire)         AC withstand voltage (wire - wire)         Power frequency withstand voltage (wire - jacket)         Flame resistance         chemical resistance	Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.         yes         P83         black 1, black 2, black 3, green-yellow, blue, blue         PVC         6         3,1 mm         ± 5 %         1,5 mm²         2,5 kV         IEC 60332-2-2   UL 1581 § 1100 FT2   UL 1581 § 1090         Good, application-related testing

The information in this Product-PDF has been compiled with the utmost care. Liability for the correctness completeness and topicality of the information is restricted to gross negligence. Version: 2024-05-18

Murrelektronik bv | Noorderlaan 147-b9 | B-2030 Antwerpen | Fon +32 (0)380 868 81 | Fax | shop@murrelektronik.be | shop.murrelektronik.be